


Southern Company Generation  
 LOTO ISOLATION Record

PLAINTIFF'S  
 EXHIBIT  
 8

Company

LOTO #: OP-01-GRP-00027		Equipment: U2-TURBINE		Equipment #: OLI002-FL-TU-3000	
<b>LOTO Information</b>					
Plant: Oliver Dam		Requested By: Keene, Christopher, M		Date/Time Needed: 5/20/20 0917	
Reason for LOTO: lower and tag head gates to unwater the unit for inspection					
Special Instructions:					
Issued By: Keene, Christopher, M		Lock Box #: OP-1-5-009		Single Locks:	
<b>COPY</b>					
Executed By: Keene, Christopher, M		Signature 		Verified By: Devero, Robert	
				Signature 	

Tag #	Boundary					Operating Area				
	Device	Device #	Position	Tag Type	Locking Device	Executed By	Test Method	Test Perf. By	Verifier	Notes
1	U2-EAST HEADGATE	OLI002-FP-VL-3000E	CLOSED	RED			VISUAL		RD	
2	U2-MIDDLE HEADGATE	OLI002-FP-VL-3000M	CLOSED	RED			VISUAL		RD	
3	U2-WEST HEADGATE	OLI002-FP-VL-3000W	CLOSED	RED			VISUAL		RD	
4	U2-PENSTOCK PRIMING VALVE	OLI002-FP-VL-3003	CLOSED	RED			VISUAL		RD	

**Additional Equipment:**

LOTO #: OP-01-GRP-00027	Equipment: U2-TURBINE	Equipment #: OLI002-FL-TU-3000
<p style="text-align: center;">Comments</p> <p style="text-align: center; color: red; font-size: 2em; font-weight: bold;">COPY</p>		

LOTO BOUNDARY DECREASE Record

LOTO #: OP-01-GRP-00027		Equipment: U2-TURBINE			Equipment #: OLI002-FL-TU-3000		
LOTO Information							
Plant: Oliver Dam		Requested By: Keene, Christopher, M			Date/Time Needed: 5/20/20 0917		
Reason for LOTO: lower and tag head gates to unwater the unit for inspection							
Reason for Variance: Check priming valve for leaks							
Issued By: Nelms, Jason, F				Lock Box # OP-1-5-009		Single Locks:	
Executed By: Nelms, Jason, F			Signature <i>J Nelms</i>				
Boundary				Operating Area			
Tag #	Device	Device #	Position	Tag Type	Locking Device	Executed By	Notes
4	U2-PENSTOCK PRIMING VALVE	OLI002-FP-VL-3003	CLOSED	RED	<i>cable</i>	<i>JN</i>	

COPY

Additional Equipment:	
<b>COPY</b>	
Comments	

Southern Company Generation  
**LOTO BOUNDARY INCREASE Record**



**COPY**

LOTO #: OP-01-GRP-00027		Equipment: U2-TURBINE			Equipment #: OLI002-FL-TU-3000					
<b>LOTO Information</b>										
Plant: Oliver Dam		Requested By: Keene, Christopher, M			Date/Time Needed: 5/20/20 0917					
Reason for LOTO: lower and tag head gates to unwater the unit for inspection										
Reason for Variance: restore original Loto										
Issued By: Nelms, Jason, F				Additional Lock Box #			Additional Single Locks:			
Executed By: Nelms, Jason, F		Signature <i>J Nelms</i>		Verified By: Devero, Robert			Signature <i>Robert Devero</i>			
Boundary					Operating Area					
Tag #	Device	Device #	Position	Tag Type	Locking Device	Executed By	Test Method	Test Perf By	Verifier	Notes:
	U2-Penstock Raising VLV	OLI002-FL-VL-3003	closed	RED	cabole	JN	Drain	JN	RO	

LOTO #: OP-01-GRP-00027	Equipment: U2-TURBINE	Equipment #: OLI002-FL-TU-3000
<b>Additional Equipment:</b>		
<b>Comments</b>		

**COPY**